

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 743

Dated: 20/4/18

**FIRE SAFETY CERTIFICATE**

Certified that **Tagore International School** located at Paschimi Marg, Vasant Vihar, New Delhi-110057 comprised of four interconnected blocks (Two blocks are ground plus two upper floors & Two blocks are ground plus three upper floors) was issued FSC by this department vide letter No. F.6/MS/DFS/School/2014/SZ/1558 Dated 11/12/2014. The premise was re-inspected by officer concerned of this department on 10/04/2018 in the presence of Sh. Harvinder Singh (Admin) and found that the school premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. 262-362 dated 17.01.2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 20/4/18 at New Delhi by

*Vipin Kental*

**(Vipin Kental)  
Chief Fire Officer**

Copy to: -

1. Principal, Tagore International School, Paschimi Marg, Vasant Vihar, New Delhi-110057
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."